

EBCE Critical Municipal Facilities  
Program  
**Emeryville**  
**List for Initial Analysis**

| Service Address             | SA Billed<br>kWh<br>Previous<br>Year | SA Billed<br>kWh Current<br>Year | City Facility Name    | Notes   |
|-----------------------------|--------------------------------------|----------------------------------|-----------------------|---|
| 1333 PARK AVE               | 335167                               | 183319                           | Civic Center          | Existing solar, may be at end of useful life. Solar owned by City.  |
| 2449 POWELL ST.             | 163198                               | 83558                            | Police Dept           | Solar may not be working. Possible microgrid site. MA - Notes as of Nov 21 sitewalk - Installed: 2012, inverter 25 KWH. Can't check production. The display needs to be replaced.         |
| 1220 53RD ST.               | 67669.14                             | 31399.98                         | Child Development Ctr | Roof has previously been deemed unsuitable for solar, but ?.  |
| 2333 POWELL ST.             | 53240.7004                           | 26208.22                         | AC Fire Station 34    | Has a very small PV panel. Next door to 2449 Powell - possible microgrid site. MA - notes as of November 2021 sitewalk, Installed:2014, inverter 10 KWH Currently producing about 3.5 KWH |
| 6303 HOLLIS ST.             | 50067.8                              | 23092.2                          | AC Fire Station 35    | Roof has previously been deemed unsuitable for solar, but ?. EOC located here too.  |
| SW 63-HOLLIS BACK OF FS #35 | 9874.3307                            | 5809.3938                        | Fire Station #35      | This is part of AC Fire Station 35, listed above.   |
| 4321 SALEM ST.              | 3,738.00                             | 514                              | Senior Center         | Does the City own this solar? How old is it? This was installed in about 2017. We own it.   |